



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM #2

RFP #7550805

TITLE: GENERATOR REPLACEMENT – KINGSTON STATION

SUBMISSION DEADLINE: 8/15/16 – 11:00 a.m.

Answers to questions received are provided for use in preparing your bid offer:

1. What size/how many hrs run time sub base fuel tank is required
24 hour rated base fuel tank
2. What size/amperage transfer switch is required
One (1) 260 Amp Automatic Transfer switch, to be used on 120/208 volt, 60 hertz, 3 pole,
4 wire in NEMA1 enclosure.
3. Does the generator enclosure need to be sound attenuated and do they want steel or
aluminum
Structural steel base, vibration isolators and weather protective enclosure.
4. Do they need a remote annunciator alarm panel
Yes. NFPA 110 Remote annunciator panel.

Additionally awarded vendor must provide initial fill of lubricating oil and ethylene glycol, as well as
a Two Year Warranty from Date of Start-Up.

Lisa Hill

Lisa Hill
Chief Buyer