



**State of Rhode Island  
Department of Administration / Division of Purchases  
One Capitol Hill, Providence, Rhode Island 02908-5855  
Tel: (401) 574-8100 Fax: (401) 574-8387**

**Solicitation Information  
October 12<sup>th</sup>, 2017**

**ADDENDUM # 2**

**RFQ# 7565482**

**TITLE: Security System Improvements at RITS**

**Submission Deadline has been extended to:**

**Friday October 20<sup>th</sup>, 2017 at 1:30 pm (EST)**

**Note to vendors:**

**Attached includes:**

- **Questions received with answers. No more questions will be answered.**
- **Sign-in sheet from mandatory prebid conference. Only proposals from vendors in attendance will be considered for award.**

**Max Righter  
Buyer II**

*Interested parties should monitor this website, on a regular basis, for any additional information that may be posted*



State of Rhode Island, Department of Administration  
Division of Purchases  
One Capitol Hill  
Providence, Rhode Island 02908  
www.purchasing.ri.gov 401-574-8100

## Questions Received

### Solicitation #7565482

### Security System Improvements at RITS

1. Can we re-use the intercom rack

*Answer: Yes, assuming new intercom equipment will be able to fit into existing intercom rack.*

2. Can we re-use the intercom rack

*Answer: see above.*

3. Will a non-proprietary Allen Bradley PLC system be acceptable (See attached cut-sheet)

*Answer: No, the Allen Bradley is not compatible with the specified MTI PLC system.*

4. Will a non-proprietary Harding digital intercom system with VoIP master stations be acceptable for the intercom system (See attached cut-sheet)

*Answer: Yes, provided the new digital intercom system is fully compatible with the new PLC system, access control system and IP video system to provide functionality as specified.*

5. What will the length of the new duct bank be for the fiber optic cabling installation?

*Answer: Approximate length is 4000 feet.*

6. Will existing as-built drawings be provided prior to the bid submission for calculations of Category 6 cables required?

*Answer: No.*

7. Is the facility expecting the camera's to be completely re-wired with Category six rated cabling?

*Answer: No, provide encoders for all existing analog cameras as specified. New wiring shall be provided as required to support the new security systems specified.*

8. Will Genetec Certified Channel Partner's be allowed to bid?

*Answer: Yes, provided the Genetec certified Channel Partner can self-perform all security systems including the PLC system, intercom system, and access control system.*



# "MANDATORY" PRE-BID CONFERENCE SIGN IN SHEET

Mandatory Pre-bid Conference: Any vendor who intends to submit a bid proposal in response to this solicitation must have its representative attend this mandatory prebid conference, sign, and complete all required information on this Sign-In Sheet. Failure to comply with this requirement will result in the rejection of any bid proposal.

BID NUMBER: 7565482

BID TITLE: Security System Improvements at RITS

PRE-BID DATE AND TIME: October 2, 2017 at 10:00 am

Purchasing Representative:

Max Righter

Mandatory Pre-bid START TIME:

9:05

Mandatory Pre-bid END TIME:

9:35

COMPANY NAME	COMPANY REPRESENTATIVE	SIGNATURE	ADDRESS	CONTACT E-MAIL	CONTACT PHONE NUMBER
1. State Purchasing	Max Righter		1 Capital Hill, Providence RI	Max.Righter@Purchasing.ni.gov	401-514-8174
2. Stanley Security	Scott F. Moyer		8251 Fishers Dr. Indianapolis, IN	Scott.Moyer@5801rx.com	610-607-4080
3. Signet	Jason Bianco		120 Leander Drive Norwell, MA	Jason.Bianco@signetcorp.net	781-871-5888
4. Signet	Greg Hussey		980 Leander Drive Norwell, MA 02061	greg.hussey@signetcorp.net	781-871-5888
5.					
6.					
7.					
8.					
9.					
10.					
11.					
12.					
13.					
14.					
15.					
16.					
17.					