



# Request for Quote

STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS  
ONE CAPITOL HILL  
PROVIDENCE RI 02908

CREATION DATE : 16-MAY-18  
BID NUMBER: 7592743,1  
TITLE: FURNISH AND INSTALL A PRE-FABRICATED WALK-IN REFRIGERATOR AT CHAPIN HEALTH LAB  
  
BLANKET START : 18-MAY-18  
BLANKET END : 31-DEC-18  
BID CLOSING DATE AND TIME:23-MAY-2018 10:30:00

BUYER: Cadoret, David  
PHONE #: 401-574-8131

B  
I  
L  
L  
L  
T  
O  
DOA CONTROLLER  
ONE CAPITOL HILL, 4TH FLOOR  
SMITH ST  
PROVIDENCE, RI 02908  
US

S  
H  
I  
P  
T  
O  
DOA BUDGET OFFICE  
ONE CAPITOL HILL, 4TH FLOOR  
SMITH ST  
PROVIDENCE, RI 02908  
US

Requisition Number: 1558056

Note to Bidders: SEE ATTACHED DOCUMENTATION

Amendment Description: THIS ADDENDUM POSTS ANSWERS TO QUESTIONS SENT IN ON LINE

Line	Description	Quantity	Unit	Unit Price	Total
1	Provide, Assemble, and Install a Pre-fabricated Walk-in Refrigerator at Chapin Health Lab (as per attached specifications). Bid a total cost.	1.00	Each		

Delivery: \_\_\_\_\_

Terms of Payment: \_\_\_\_\_

It is the Vendor's responsibility to check and download any and all addenda from the RIVIP. This offer may not be considered unless a signed RIVIP generated Bidder Certification Cover Form is attached and the Unit Price column is completed. The signed Certification Cover Form must be attached to the front of the offer



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: [www.purchasing.ri.gov](http://www.purchasing.ri.gov)

**May 16, 2018**  
**ADDENDUM NUMBER ONE**  
**RFQ # 7592743**

**TITLE: FURNISH AND INSTALL A PRE-FABRICATED WALK-IN REFRIGERATOR AT  
CHAPIN HEALTH LAB**

**Closing Date and Time: 5/23/18 AT 10:30AM**

**Per the issuance of this ADDENDUM #1 (1 page) the following is noted:**

This addendum answers questions sent in on line.

1. Are union or prevailing wage labor required for the installation?  
**A. Prevailing wage rates applies.**
2. Is the cold room manufacturer responsible for building electrical power to the equipment? It's listed in the contract documents as such. Typically, manufacturers provide points of connection, while building power and final connections are handled by others. Please advise.  
**A. The vendor installing the cooler shall coordinate with the manufacturer and his electrical sub-contractor to ensure proper electrical connection and commissioning of the equipment to make sure the terms of the warranty are maintained.**
3. Specifications call for an M600 full roller pallet and a M600 End/Side Load full roller pallet. Please advise which one is required.  
**A. Desired product is the Series M601 Full Roller Pallet Assembly. Following specs are required:**
  - **Maintenance-free conveyor rollers for easy transfer**
  - **Can be used from either end for loading or unloading**
  - **Flip-style tray stops at each end with bumper protection**
3. It appears in the bid documents you must be a prime contractor with a RI contractor's license.  
**A. Manufacturer able to submit bid and sub job to licensed contractor**

**END OF QUESTIONS**