



State of Rhode Island  
Department of Administration / Division of Purchases  
One Capitol Hill, Providence, Rhode Island 02908-5855  
Tel: (401) 574-8100 Fax: (401) 574-8387

Solicitation Information  
October 10<sup>th</sup>, 2018

ADDENDUM # 5

**RFQ# 7596675**

**TITLE: Water Treatment**

**Submission Deadline is:**

**Friday October 19<sup>th</sup>, 2018 at 10:30 am (EST)**

**Note to Vendors:**

- **This addendum is to provide clarification to the bid specifications and requirements:**
  - The specifications for the DOC water treatment bid indicate( 5 cooling towers) ,Intake south ,Intake North, High Security, Woman's Facility and Reintegration . We only received cooling tower tons for 4 towers ,I believe eliminating Reintegration. There are only 4, Intake South, Intake North, Woman's, and Medium. High Security is air cooled, Reintegration has been removed.
  - Based on the RFP there are 5 cooling towers. It appears you are missing information on the Integration Open Circulating system. To accurately quote we need that information. See above.
  - The RFQ Line 13-16 states bi weekly testing for Legionella. However the Scope of work Paragraph 4 states monthly testing. Testing is Monthly

**Max Righter  
Buyer II**

*Interested parties should monitor this website, on a regular basis, for any additional information that may be posted*