



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

December 18, 2018
ADDENDUM NUMBER FIVE
RFQ # 7597618

TITLE: EMERGENCY GENERATORS AT STEDMAN CENTER AND HARRINGTON HALL

Closing Date and Time: 1/4/19 AT 2:30PM

Per the issuance of this ADDENDUM #5 (1 page) the following is noted:

This addendum changes specifications as noted below:

1. Drawing 00-E-1; Delete Detail A, "Typical Padmount Switch #4 & Grounding Detail."
2. Drawing 00-E-2; Ductbank Sections, delete #1/0 Ground Run in Ductbank.
3. Drawing 00-E-3; Delete; Elevations B, C, D and E, for Padmount Switch and Cabinets.
4. Drawing 58-E-1; Delete New 5kV Padmount Switches To Replace Existing Cabinets 4A and 4B. This work will be done under a separate contract.
5. Drawing 58-E-1; Primary to New Padmount Transformer shall be 3 – 350 MCM 5kV & 1 # 3 Ground connected to elbows/tees in existing cabinet. Remove existing primary cable.
6. Drawing 58-E-1; Secondary from New Padmount should be revised to be indicated to be run to the electric room and not the generator.