



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM #7

RFQ#7597658 TITLE: RIDOT MATERIALS LABORATORY RENOVATIONS

SUBMISSION DEADLINE: JANUARY 30, 2019 – 2:00 p.m.

Question received as follows:

Regarding: The answer to question #4 on Addendum #6 regarding Drawings M-101, M-102, & M-103 that shows duct work going thru existing partitions.

- The drawing supplied by addendum #6 isn't clear at all. Respectfully, there is no way of determining what walls are masonry and non-masonry. In addition, there is no way to determine how thick the walls are. In addition, the answer doesn't address if the masonry walls (which we still can't determine which ones are masonry) are structural. Please provide a wall type and thickness for each of the walls effected and any structural requirements if necessary. This will provide all the general contractors with the same data in order to bid the project based on the same data.

Answer as follows:

- All interior walls are assumed to be not load bearing. Wall materials are identified per the sketch.

QUESTION PERIOD NOW CLOSED. NO FURTHER QUESTIONS WILL BE ALLOWED.

Lisa Hill

Lisa Hill
Assistant Administrator