



**State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387**

ADDENDUM # 2

1/17/19

Solicitation #7597662

Title: Water Tank Replacement – Community College of Rhode Island

Submission Deadline: January 24, 2019 @ 1:00 PM


Per the issuance of ADDENDUM #2 the following are noted:

Addendum #2, see attached.

No questions or substitute requests were submitted.

Interested Parties should monitor this website on a regular basis, for any additional information that may be posted.

**Gary P. Mosca
Chief Buyer**



COMMUNITY COLLEGE OF RHODE ISLAND, NEWPORT CAMPUS: Water Tank Replacement #7597662

ADDENDUM 2: NEWPORT WATER TANK REPLACEMENT

January 17, 2019

1. Additional Scope Item, 1.2.A.14: reparation work such as removal of the door and wall for the tank can be done first shift during the week. Reinstallation of the door, frame, wall and painting work can be completed first shift.
2. Additional Scope Item, 1.2.A.15: The scope is to drain the system starting on Friday evening at 10:00 PM, replacing the complete tank system on Saturday and Sunday, refilling domestic water system and being operational by Sunday afternoon on the same weekend that the system was drained.
3. Additional Scope Item, 1.2.A.16: A Manufacturing Representative will be required to be onsite the Monday after the installation is complete on Sunday for final acceptance of the system.
4. Additional Scope Item, 1.2.A.17: This vendor will be allowed to have the tank and materials delivered to the Campus and stored in the Garage basement prior to commencing all work.
5. Additional Scope Item, 1.2.A.18: The existing circulator pumps are to be replaced with new pumps.
6. Additional Scope Item, 1.2.A.19: The existing mixing valve is to be replaced with a new mixing valve.
7. Additional Scope Item, 1.2.A.20: All valves are to be replaced on all vertical pipes; valves on horizontal pipes nearest the ceiling are not to be replaced.
8. Additional Scope Item, 1.2.A.21: This vendor is to include all electrical work as required for this installation.
9. Additional Scope Item, 1.2.A.22: This vendor is to furnish and install a new water tank including the turbo power gas burner and all associated piping and controls for a complete system.
10. Scope item 1.2.A. 6 Clarification: This system is to be completely operational Sunday afternoon. A 25 year warrantee is required per the Bid Documents, therefore any modifications to the existing ductwork as required by the manufacturer of the packaged 400 gallon water tank system to issue this warrantee is to be included in this Bid Cost.

11. Additional Scope Item 1.2.A.23: All closeout documents and warranties to be turned over to the college within 2 weeks of completing the project.

12. Additional Scope Item 1.2.A.24: The old existing expansion tank is to be turned over to the college.

End.