



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

February 28, 2019

ADDENDUM # 5

Bid # 7598559

**Title: CONSTRUCT 3 BAY GARAGE ADDITION AT MS-ANG COVENTRY
P-6 BASE**

Bid Closing Date & Time: Thursday March 7, 2019 at 1:30 PM

Notice to Vendors:

**Correction to: ELECTRICAL REFEED DIRECTION FOR P8 AND FRONT
ENTRY GATE.**

**Kathy Missell
Chief Buyer**

Interested parties should monitor this website, on a regular basis, for any additional information that may be posted.

TO ALL BIDDERS OF RECORD:

This Addendum forms a part of the Contract Documents and modifies the Drawings and Project Manual as hereinafter indicated.

ADDENDUM 003 2/27/2019

ELECTRICAL REFEED DIRECTION FOR P8 AND FRONT ENTRY GATE

Power Connection to Existing Building P8 and Front gate: Refeed loads for Bldg. P8 and Entry Gate from the new switchgear. Will need to provide a 225amp circuit breaker in the new switchboard and 4#4/0&1#4G to refeed the buildings. Provide a pull box in mechanical room and tie in the underground feed to buildings 8 and 12

(THIS COMPLETES ADDENDUM NO. 003)