



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM # 3

4/25/19

Solicitation #7598701

Title: Integrated Manufacturing Center Renovations – Knight Campus CCRI

Submission Deadline: May 3, 2019 @ 1:30 PM


Per the issuance of ADDENDUM #3 the following are noted:

Please find attached Addendum prepared by Aharonian & Associates Inc. - **Clarification to Project Manual**

No further questions will be entertained.

Interested Parties should monitor this website on a regular basis, for any additional information that may be posted.

Gary P. Mosca
Chief Buyer



AHARONIAN
& ASSOCIATES, INC.
Architects

April 24, 2019

TO: All Bidders

RE: CCRI INTEGRATED MANUFACTURING CENTER RENOVATION
KNIGHTCAMPUS
400 East Ave
Warwick, RI 02886

ADDENDUM #3

CLARIFICATION TO PROJECT MANUAL

Specification Section 23 00 00 shall be modified as follows:

2.17 Wood Dust Collector:

T. Nema 12 UMA Controller - Remove this sub-section

2.18 Metal Dust Collector:

D. Explosion Relief Vents - This sub-section shall apply to both 2.17 & 2.18.

H. 70 dBA Silencer - This sub-section shall apply to both 2.17 & 2.18.

I. Control Panel, Airflow Controller & Variable Frequency Drive - This sub-section shall apply to both 2.17 & 2.18.

J. Hopper: shall be complete with drum cover & slide gate. Drum shall be provided by GC as noted on schedule.

L, M, N, O, P & Q - These sub-sections shall apply to both 2.17 & 2.18.