



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration  
DIVISION OF PURCHASES  
One Capitol Hill  
Providence, RI 02908-5855

Tel: (401) 574-8100  
Fax: (401) 574-8387  
Website: [www.ridop.ri.gov](http://www.ridop.ri.gov)

**July 11, 2019**  
**ADDENDUM NUMBER THREE**  
**RFQ # 7598843**  
**TITLE: GENERATOR FOR YOUTH DETENTION FACILITY**

**Closing Date and Time: 7/26/19 AT 10:00AM (Note change)**

Per the issuance of this ADDENDUM #3 (1 page and PDF files) the following is noted:

**This addendum changes bid closing date and time from:**  
**7/19/19 at 10am**  
**To**  
**7/26/19 at 10am**

This addendum posts revised drawings not posted in addendum two (2).  
This addendum posts additional information to bid specifications.

**Propane Tank**

The tank capacity is 120 gal. / 420 lb. The tank is 54.5" tall with a diameter of 30".  
The vendor is Ferrellgas.

Pad dimensions for the propane tank are accurate as indicated on SA-501; 12'-6" x 24'. The scale for CS-100 is (1" = 20') and CS-102 is (1" = 5'). All other scales are correct. Revised drawings provided.