



**State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387**

**Solicitation Information
August 6, 2019**

ADDENDUM # 2

**RFQ# 7598891
TITLE PERIMETER TRAIL CULVERT REPLACEMENT**

**Submission Deadline has been postponed until:
Wednesday August 14, 2019 at 11:00 AM**

Notice:

- Attached includes questions received with responses

Interdepartmental Project Manager

Interested parties should monitor this website, on a regular basis, for any additional information.

NOTICE TO PROSPECTIVE BIDDERS

Prospective bidders and all concerned are hereby notified of the following changes/modifications to the Perimeter Trail Culvert Replacement Project, Camp Fogarty, East Greenwich, Rhode Island. **These changes shall be incorporated into the Contract Manual and shall become an integral part of the Contract Documents.**

1. **Question:**

Can a precast headwall be utilized in lieu of cast in place?

Clarification:

A precast alternative may be permitted. It shall be the Contractor's responsibility to ensure the alternative means and methods are achievable within the proposed project schedule, and appropriate time is allowed for submittal preparation, review, and precast operations. Appropriate methods of delivery and picking shall also be considered within the context of the project area.

2. **Question:**

Are wing walls required?

Clarification:

Yes. The project was designed and permitted with wing walls.

3. **Question:**

I am looking to see if there is a project estimate available for this project?

Clarification:

A project estimate will not be provided for this project.