



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM #4

RFQ #7598903

TITLE: EAST PROVIDENCE SALT STORAGE FACILITY

SUBMISSION DEADLINE: 8/27/19 – 1:00 P.M.

Answers to questions received are below:

- Are there any FA requirements for this structure? **No**
- Is any exterior lighting required? **No**
- Sheet E101, Note 2, specifies "PVC Conduit Coated". Is that to mean PVC Conduit or PVC Coated Rigid Steel Conduit? **PVC Coated Rigid Steel Conduit.**
- Is stainless steel hardware required for conduit support? **Yes**
- Is there a specification for the structure that shows truss layout available? This will affect fixture installation methods. **Please refer to response by the Architect/Structural Engineer for this item.**
- Is there a fixture mounting and height detail available? Ironhorse Structures is typically a 3" Tubular Truss. **Please refer to response by the Architect/Structural Engineer for this item.**
- Addendum 2 contains information about a treatment system (reports, data and components). Please advise if this is part of this project or just for informational purpose only. **There is a specification for the system and this is the related RIDEM permit submittal and approval. It is unlikely that this will be needed because of the rammed aggregate pier approach.**

Lisa Hill

Lisa Hill
Assistant Administrator