

September 6, 2019

STATE OF RHODE ISLAND AND PROVIDENCE PLANTATION
DEPARTMENT OF ADMINISTRATION

DIVISION OF PURCHASES BID NO. 7598922

RHODE ISLAND DEPARTMENT OF TRANSPORTATION

RHODE ISLAND CONTRACT NO.2019-CB-058

FEDERAL-AID PROJECT NO. FAP Nos: BRO-PRES(007)

Bridge Group 03 - I-95 PAW

Interstate 95 (Moshassuck River to Central Avenue), City of Pawtucket

CITY/TOWN OF Pawtucket

COUNTY OF PROVIDENCE

NOTICE TO PROSPECTIVE BIDDERS


ADDENDUM NO. 2 Prospective bidders and all concerned are hereby notified of the following changes in the Plans, Specifications, Proposal and Distribution of Quantities for this contract. These changes shall be incorporated in the Plans, Specifications, Proposal and Distribution of Quantities, and shall become an integral part of the Contract Documents.

A. Specification Change/Addition

1. Page CS-11

Remove page CS-11 in its entirety and replace it with revised page CS-11 (R-1) attached to this Addendum No. 2.

Section 9 "SPECIALTY ITEMS" has been revised. Repainting Existing Structural Steel Superstructure in its Entirety has been added to the list of Specialty Items.



RI Department of Transportation

Administrator, Division of Project Management

ADDENDUM NO. 2

ATTACHMENTS

NGRID Gas requires 4 week advance notification of any changes to the predetermined schedules of construction.

Due to system reliability and safety concerns, it is National Grid's practice to restrict all construction on or near gas facilities between November 15th and April 15th. All scheduled work should be completed between April 15th and November 15th. As gas usage peaks during the months of December to March driven by heating needs, National Grid's priority is to provide their customers with safe and reliable service. Any work on or near the gas facility will expose their customers to unnecessary risk. Exceptions will be considered on a case by case basis. Approvals from Gas Control, Operational Engineering and Project Engineering will be required for these cases.

Pawtucket Water Supply Board (PWSB)

PWSB will be present on site when the Contractor is working adjacent to the water lines supported by the superstructure of: **Main Street Bridge No. 546, Walcott Street Bridge No. 555, Broadway Bridge No. 558 and Fountain Street Bridge No. 559.**

All the above referenced shop drawing submittals shall be submitted simultaneously to the respective utility, the Engineer, and the Design Consultant. Refer to Special Provision Code 105.02 for plan and shop drawing submission requirements.

Unless noted otherwise above, it is also required that the Contractor notify each utility no less than two (2) weeks in advance of the date and time that the Contractor intends to work in the vicinity of the utility's facility.

9. SPECIALTY ITEMS

The following items are hereby designated as "Specialty Items" for this project.

- a. Asphaltic Expansion Joint System
- b. Signage
- c. Pavement Markings
- d. Guardrail
- e. Fencing
- f. Repainting Existing Structural Steel Superstructure in its Entirety