



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

Solicitation Information
October 25, 2019

ADDENDUM # 3

RFQ# 7599799

TITLE: Roof Replacement / Envelope Repair at RISP Headquarters, North Scituate

Submission Deadline has been extended until:

Thursday October 31, 2019 at 11 AM (Local Time)

Notice:

- Attached includes
 - o Additional information

Interdepartmental Project Manager

Interested parties should monitor this website, on a regular basis, for any additional information.



Addendum #03

24 October 2019

To: All Prospective Bidders
 Re: Addendum 03
 RI State Police HQ Roof Replacement (1809)

The attention of Bidders submitting proposals for **RI State Police HQ Roof Replacement** is called to this addendum to the Contract Documents: the Project Manual and/or Drawing Set for Construction, dated **19-0703**, prepared by LLB Architects.

The Items set forth herein, whether of revision, omission, addition, substitution, or clarification are all to be included as part of the Contract Documents. The addendum modifies the project manual and/or drawings as indicated. Portions of the Contract Documents not altered by this addendum shall remain in full force.

The number of the addendum must be entered in the appropriate spaces on the required bid form(s) to acknowledge receipt of the said addendum. Failure to acknowledge the said addendum could subject the bidder to disqualification.

It shall be the responsibility of each general bidder to notify all subcontractors and suppliers he proposes to use for various parts of the work for any changes or modifications contained in this addendum. No claim for additional compensation because of lack of knowledge of the addendum will be considered.

Part 1 - Questions

Q1 Is the EPDM White or Black, it seems that the Roof Nav Number no longer supports White Membrane, only Black?
RESPONSE: The intent, based on the roof nav number is a black membrane.

Part 2 - Project Manual/Specifications

Item #	Section#	Section Description	Section Issued
		REVISE specification section as follows: 1.2, A, to ADD 10. Installation of Elastomeric White Roof Coating at RTU intakes. 1.5, B, to ADD 8. Limits of Elastomeric White Roof Coating at RTU intakes.	
S1	07 53 23	2.2, A, 3. Color: EcoWhite Platinum, Black . 2.3, M, 1. white black ... (occurs twice). 2.4, N. Liquid Coating: <u>Elastomeric White Roof Coating Product</u> specifically formulated for coating EPDM membrane roofing accessories that do not match white membrane, <u>at RTU intakes</u> as follows:	NO

Part 3 - Drawings

Item #	Drawing #	Drawing Description	Drawing Issued
None.			

Part 4 - Attachments

- General none
- Specifications none
- Drawings none
- Sketches none

Respectfully,

LLB Architects
Brian L. Valentine, AIA

End Addendum 03