



State of Rhode Island  
Department of Administration / Division of Purchases  
One Capitol Hill, Providence, Rhode Island 02908-5855  
Tel: (401) 574-8100 Fax: (401) 574-8387

March 6, 2020

**ADDENDUM # 2**

**Bid # 7599930**

**Title: Lighting Upgrades DOT Building (4 locations)**

**Bid Closing Date & Time: March 25, 2020 at 11:00 AM**

**Notice to Vendors:**

1. Answers to Questions
2. Clarifications
3. New Revised Fixture Inventory Table

**Kathy Missell  
Chief Buyer**

*Interested parties should monitor this website, on a regular basis, for any additional information that may be posted.*

Solicitation #: 7599930 Lighting Upgrade DOT Buildings (4 Locations)  
Addendum2

1. Bidders are not responsible for preparing or submitting incentive applications for these lighting projects.
2. Document: RFQ Lighting 4 DOT Garages – RIVIP Vendor Certification Cover Form
  - a. Page 1. Replace Rethinking Power Management address with 416 West Broadway, Suite 203, Boston, MA 02127
3. Document: 20191107 RIDOT Lighting RFQ Scope of Work - Midstate Bellville Scituate Hope Valley,
  - a. Page 1. Replace:
 

*References to specific products or brands, where provided are for reference only and should be interpreted to mean "or equivalent". Contractors are expected to provide information about recommended products and rationale for selection in sufficient detail for the RIDOT Project Manager to make informed choices.*

With:

*The proposed fixture numbers listed in the Revised Table 1 Fixture Inventory are preferred by RIDOT. Bidders are required to provide pricing for these products. Alternative products will not be considered at this time.*
  - b. Page 1. Replace
    - 1.b. *The Contractor will furnish and install approximately (438) new LED lighting fixtures in the designated areas of the buildings as detailed in Table 1.*
  - c. With:
 

*The Contractor will furnish and install approximately (449) new LED lighting fixtures in the designated areas of the buildings as detailed in Table 1.*
  - d. Page 4. Replace Table 1 Fixture Inventory in the RFQ with the Revised Table 1 Fixture Inventory.

**Revised Table 1 Fixture Inventory**

Scituate			Existing Fixture Info		Proposed Fixture Info - Revised		
Line #	Location ID #	Location Room Name	Existing Fixture QTY	Existing Fixture Name	Proposed System QTY	Proposed Fixture/ or Equivalent	Proposed Fixture Wattage [W]
1	1	Entry Way	1	2L 4' T12 Strip 80w	1	E5SLB35D4-83050	37
2	1	Entry Way	1	100W incand spot light	1	Par 38	15
3	2	Super's Office	1	60W incand floor lamp	1	A19	8
4	2	Super's Office	2	2L 8' T12 Strip 80w	4	E5SLB35D4-83050	58
5	3	Kitchenette	1	2L 4' T12 Strip 80w	1	E5SLB35D4-83050	37
6	4	Foreman's Office	3	2L 4' T12 Strip 128w	3	E5SLB35D4-83050	37
7	5	Break room	4	2L 8' T12 Strip 80w	8	E5SLB35D4-83050	58

8	6	Garage Interior	12	250W HPS High Bay	12	E2HBA-M150[z]-840AL	130
9	7	Bathrooms	3	2L 8' T12 Strip 80w	6	E5SLB35D4-83050	58
10	8	Mechanics workshop	3	2L 8' T12 Strip 80w	6	E5SLB35D4-83050	58
11	9	Ext. Parking lots	4	250W MH Flood LT Roof	4	E3SB100L3-750	100
12	10	Salt Shed	10	250W HPS Salt Cans	10	E1HBC150-740	100
13	10	Ext.	1	100w knuckle	1	E1AFL50DL-750	50
14	10	Ext. Parking lots	2	250w area Fuel Station	2	E3SB100L3-750	80
15	10	Door Mt Flood	2	50w Incandescent	2	E1AFL50DL-750	20
16	11	Ext. Lighting	3	250W MH Wall Pac FT PC	3	E2WPA60L-750	69
17	12	Storage Shed	1	2L 4' T8 Strip 64w	1	E5SLB35D4-83050	29
18	13	Street Lights	4	400W HPS Cobra Head S/L	4	E2ST2B150L-750	150
			<b>58</b>		<b>70</b>		<b>N/A</b>

Belleville			Existing Fixture Info		Proposed Fixture Info - Revised		
Line #	Location ID #	Location Room Name	Existing Fixture QTY	Existing Fixture Name	Proposed System QTY	Proposed Fixture/ or Equivalent	Proposed Fixture Wattage [W]
1	1	Entry Way	2	2L 4' T8 Strip 64w	2	E5SLB35D4-83050	37
2	2	Super's Office	3	3L 4' T8 recess 96w	3	E5SLB35D4-83050	37
3	3	Clerk's Office	3	3L 2' T8 recess 84w	3	ELYTD4-2X2NED	26
4	4	Special Mech Bay	6	250W HPS susp Can	6	E2HBA-M150[z]-840AL	130
5	5	Garage Bay Interior	12	250W HPS susp Can	12	E2HBA-M150[z]-840AL	130
6	6	Foreman's Office	10	2L 2' T8 recess 64w	10	ELYTD4-2X2NED	26
7	7	Break room	8	3L 4' T8 recess 96w	8	ELYTD4-2X4NED	34
8	8	Stock Room	8	2L 8' T12 Strip 170w	8	E5SLB35D4-83050	82
9	9	Upper Stock Room	3	2L 8' T12 Strip 170w	3	E5SLB35D4-83050	82
10	10	Stock room Bathrooms	6	3L 4' T8 Troffer	6	ELYTD4-2X4NED	34
11	11	Inventory Office	3	3L 2' T8 recess 84w	3	ELYTD4-2X2NED	26
12	12	Cold storage interior #1	6	2L 8' T12 Strip 170w	6	E5SLB35D4-83050	82
13	12	Cold storage interior #2	10	2L 8' T12 Strip 170w	10	E5SLB35D4-83050	82
14	13	Salt Dome	8	400w HPS susp Cans	8	E1HBC150-740	150
15	14	Ext. Lights	8	250W MH Flood SF	8	E3SB100L3-750	150
16	15	Ext. Lights	8	150w MH FL KN PC	8	E1AFL50DL-750	50
17	15	Ext. Lights	1	250w Cobra	1	E2ST2B100L-750	100
18	15	Ext. Flood Lights	2	400W MH Bldg. Flood	2	E3SB150L3-750	150
19	16	Salt Hut	1	2L 4' T12 Strip 64w	1	E5SLB35D4-83050	37
20	17	Boiler Room	1	250W MH ceiling Cans	1	E2HBA-M150[z]-840AL	130
		<b>Total</b>	<b>109</b>		<b>109</b>	-	<b>N/A</b>
Hope Valley			Existing Fixture Info		Proposed Fixture Info - Revised		

Line #	Location ID #	Location Room Name	Existing Fixture QTY	Existing Fixture Name	Proposed System QTY	Proposed Fixture/ or Equivalent	Proposed Fixture Wattage [W]	
1	1	Entry Way	1	2L 4' T12 Strip 80w	1	E5SLB35D4-83050	37	
2	2	Super's Office	2	2L 8' T12 Strip 80w	2	E5SLB35D4-83050	37	
3	3	Clerk's Office	2	2L 4' T8 Strip 64w	2	E5SLB35D4-83050	37	
4	4	Garage Interior	4	250W MH Wallpack	0	remove		
5	4	Garage Interior	16	250W HPS susp Can	17*	E2HBA-M150[z]-840AL	130	
6	5	Foreman's Office	3	2L 8' T12 Strip 80w	3	E5SLB35D4-83050	37	
7	6	Break room	15	2L 2x2' T8 U tube 64w	15	ELYTD4-2X2NED	26	
8	6	Break room	2	2L 4' T8 Strip 64w	4	E5SLB35D4-83050	58	
9	7	Crawl space Attic	2	2L 8' T12 Strip 170w	2	E5SLB35D4-83050	82	
10	7	Crawl space Attic	1	2L 4' T8 Strip 64w	1	E5SLB35D4-83050	29	
11	8	Boiler Rm	1	250W HPS susp Can	1	E2HBA-M150[z]-840AL	130	
12	8	Men's Room	1	250W HPS susp Can	1	E2HBA-M150[z]-840AL	130	
13	8	Bathrooms	2	2L 2' T8 Vanity 64w	2	E3SLA10D2-840	29	
14	9	Special Bay Mech Rm	4	250W MH Wallpack	4	E2WPA60L-750	69	
15	9	Special Bay Mech Rm	1	2L 8' T12 Strip 80w	1	E5SLB35D4-83050	37	
16	10	Door Flood	2	50w Incandescent	2	E1AFL50DL-750	30	
17	10	Ext. Lights	21	150W MH Knuckle Flood	21	E1AFL50DL-750	50	
18	10	Ext. Lights	2	90W Incand spot flood	2	Par 38	15	
19	11	Salt Shed	2	150W MH Flood	2	E1AFL50DL-750	50	
20	12	Outlying Garage	8	250W MH Cans	8	E2HBA-M150[z]-840AL	130	
		<b>Total</b>	<b>92</b>		<b>92</b>		<b>N/A</b>	
		<b>*Note – Additional light added in Line 5 is to be installed in the end bay above washroom entrance.</b>						

Midstate			Existing Fixture Info		Proposed Fixture Info- Revised		
----------	--	--	-----------------------	--	--------------------------------	--	--

Line #	Location ID #	Location Room Name	Existing Fixture QTY	Existing Fixture Name	Proposed System QTY	Proposed Fixture/ or Equivalent	Proposed Fixture Wattage [W]
1	1	Entry Hall Way	6	4L 4' T8 recess 128w	6	ELYTD4-2X4NED	34
2	2	Clerk's Office	4	4L 4' T8 recess 128w	4	ELYTD4-2X4NED	34
3	3	Clerk's Storage	1	2L 4' T12 Strip 128w	1	E5SLB35D4-83050	37
4	4	Foreman's office	8	4L 4' T8 recess 128w	8	ELYTD4-2X4NED	34
5	5	Super's office	2	4L 4' T8 recess 128w	2	ELYTD4-2X4NED	34
6	6	Stock Room	1	2L 4' T8 Strip 64w	1	E5SLB35D4-83050	29
7	6	Stock Room	1	2L 4' T12 Strip 128w	1	E5SLB35D4-83050	37
8	7	Exec Bathrooms	4	4L 4' T8 recess 128w	4	ELYTD4-2X4NED	34
9	8	Foyer to Garage	2	4L 4' T8 recess 128w	2	ELYTD4-2X4NED	34

10	9	Main Garage	42	6L4'T5 susp strip 168w	42	E2HBA-M150[z]-840AL	180
11	9	Main Garage north wall	4	250W MH wall packs	0	remove	
12	10	Workshop Back Area	6	2L 4' T8 Wrap 60w	6	E5SLB35D4-83050	29
13	10	Workshop Back Area	1	2L 4' T12 Strip 128w	1	E5SLB35D4-83050	37
14	11	Break room	10	4L 4' T8 recess 128w	10	ELYTD4-2X4NED	34
15	12	Outside break room	2	2L 4' T8 Strip 64w	2	E5SLB35D4-83050	29
16	13	Frank's Room	2	2L 4' T8 Strip 64w	2	E5SLB35D4-83050	29
17	14	Manny's Room	2	2L 4' T8 Strip 64w	2	E5SLB35D4-83050	29
18	15	Mello's Room	2	2L 4' T8 Strip 64w	2	E5SLB35D4-83050	29
19	16	Labor Room	4	2L 4' T8 Strip 64w	4	E5SLB35D4-83050	29
20	17	Tool Room	2	2L 4' T8 Strip 64w	2	E5SLB35D4-83050	29
21	17	Tool Room	2	2L 4' T12 Strip 128w	2	E5SLB35D4-83050	37
22	18	Side entrance/Sand Pit	4	2L 4' T8 Strip 64w	4	E5SLB35D4-83050	29
23	19	Sign Storage	2	60W incan Fld surf mt	2	A19	8
24	20	Bathroom behind Sand Pit	1	2L 4' T8 Strip 64w	1	E5SLB35D4-83050	29
25	21	Metal Storage & Scrap	4	2L 4' T8 Strip 64w	4	E5SLB35D4-83050	29
26	22	Mechanic's Bathroom	1	4L 4' T8 recess 128w	1	ELYTD4-2X4NED	34
27	22	Mechanic's Bathroom	1	60W incand surf mt	1	A19	8
28	23	Mechanic's Bay	1	2L 8' T12 Strip 64w	2	E5SLB35D4-83050	58
29	24	Mechanic's Bay Workbench	1	2L 4' T8 Strip 64w	1	E5SLB35D4-83050	29
30	25	Mechanic's back office	2	2L 4' T8 Strip 64w	2	E5SLB35D4-83050	29
31	25	Mechanic's back office	1	2L 8' T12 Strip 120w	2	E5SLB35D4-83050	58
32	26	DG back room	10	2L4' T8 suspended 64W	10	E5SLB35D4-83050	29
33	27	Ext. Building Lighting	2	1000W MH Fld wall mt	2	VT-SBN-300W-850-TR	300
34	27	Ext. Building Lighting	5	400W MH Fld wall mt	5	VT-SBN-150W-850-TR	150
35	27	Ext. Building Lighting	3	250w MHS wallpacks	3	E2WPA90L-750	80
36	28	Parking Lot/Roadway Lighting	17	250W HPS Cobra Head	17	E2ST2B100L-750	100
37	29	Salt Shed Lighting Interior	15	400W HPS Cans Susp	15	E1HBC150-740	150
38	30	Salt Shed Lighting Ext.	2	250w MHS wallpacks	2	E2WPA90L-750	80
			<b>180</b>		<b>178</b>		<b>N/A</b>

## Q&A Responses: Lighting Upgrade DOT Buildings (4 Locations)

**Bid#: 7599930**

1. Are the submitted alternate fixtures allowable?  
**Answer: RIDOT is interested in creating consistency of lighting products across their garages. Therefore, bidders must provide pricing for the revised proposed fixture inventory provided in this Addendum. Alternatives will not be considered at this time.**
2. Will the utility incentives be assigned to the Contractor? **The State has submitted applications to National Grid for energy efficiency incentives/rebates. Once a contractor is tentatively awarded, the State will request that the Contractor reduce the price to reflect the incentive amount. Then the State will assign the rebates to the Contractor.**
3. Are the fixtures at the gasoline service area included in the solicitation, and are they required to be explosion proof?  
**Answer: No, the gasoline service area fixtures are not included in this solicitation.**