1 / M1.14 ROOF
1/8" = 1'-0"

NOTE

ROOF HOLES ONLY AT DUCT PNETRATIONS.

UNIT SHALL BE LEVEL WITHIN 1/8" IN BOTH DIRECTIONS

3 / M1.14 TYPICAL RTU
NO SCALE

2 / M1.14 3 RD FLOOR
1/8" = 1'-0"

SA·GCA Architects
An association of Saccoccio & Associates And Goody, Clancy & Associates
28 Garfield Avenue
Cranston, R.I. 02920
tel 401. 942. 7970
fax 401. 942. 7975

RENOVATION AND RESTORATION OF CENTER GENERAL COMPLEX

FOR
THE STATE OF RHODE ISLAND
DEPARTMENT OF LABOR AND TRAINING
NEW HEADQUARTERS BUILDING
PONTIAC AVENUE
CRANSTON, RHODE ISLAND

CONSULTING ENGINEERS
CATAUDELLA ASSOCIATES, INC.
1223 MINERAL SPRING AVENUE
NORTH PROVIDENCE, RI 02904
401-728-1122

7/24/98

No.	REVISIONS	DATE

KEYPLAN

TITLE:
BUILDING 73
HVAC PLAN
3RD FLOOR & ROOF

SA Job No. 97112	GCA Job No. 3940
DRAWN: XX	DATE:
CHECKED: JSC	DRAWING: 1/8"=1'-0"

J. S. CATAUDELLA
PROFESSIONAL ENGINEER

M1.14

Copyright: © SA/GCA ARCHITECTS 1997