



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.ridop.ri.gov

May 21, 2020
ADDENDUM NUMBER SIX
RFQ # 7602848

TITLE: WARWICK NATIONAL GUARD ARMORY-UPGRADES AND MODERNIZATION

Closing Date and Time: 6/16/2020 AT 10:00AM

Per the issuance of this ADDENDUM #6 (2 pages) the following is noted:

There will be a mandatory pre-bid conference to be held 6/3/2020 at 10am at:

Warwick Armory
541 Airport Rd.
Warwick, RI (rear of the building)

It is mandatory that the pre-bid conference be conducted in compliance with all State and local social distancing guidelines, including but not limited to all executive orders imposed by the State of RI and all guidelines outlined by the CDC.

All participants taking part in the pre-bid must cover mouth and nose with a face covering. Keep space between you and others. Groups may be separated to accommodate social gathering requirements in place at that time.

Please be prepared and allow extra time for delays due to possibilities of multiple walkthroughs with limited number of people in small groups in order to comply with crowd gathering in place at that time.

If you feel sick or have any symptoms related to COVID-19 please do not attend. The State reserves the right to have those individuals who show visible signs of COVID related symptoms leave the premises.

Questions concerning this solicitation may be e-mailed to the Division of Purchases at doa.purquestions14@purchasing.ri.gov no later than June 5, 2020 at 5pm. Please reference the RFQ number on all correspondence. Questions should be submitted in a Microsoft word attachment. Answers to questions received, if any, will be posted on the internet as an addendum to this solicitation (www.ridop.ri.gov). It is the responsibility of all interested parties to download this information.

Attached is Clarifications and Requirements-Integrated Fire Alarm and Mass Notification System

Warwick Armory Latrine Modernization and HVAC/Fire Alarm Upgrades to Buildings 1

8 May 2020

CLARIFICATION AND REQUIREMENTS – INTEGRATED FIRE ALARM AND MASS NOTIFICATION SYSTEM

Scope of Work

A new integrated fire alarm/mass notification system shall be provided and installed as indicated on the design documents and the mass notification system shall be as follows:

- 1) A command center in each of three buildings – Nos. 1, 2 and 3.
- 2) Command centers to include the fire alarm control panel with mass notification including voice evacuation to create and distribute live (microphone or handset) or pre-recorded messages.
- 3) Mass notification to be capable of initiation from any of the three buildings.
- 4) Mass notifications to be to all three buildings simultaneously.
- 5) Provide all interconnecting wiring between buildings as required to make the system fully functional as indicated herein.
- 6) Amber alert strobes and notification speakers shall be provided in the proximity of each fire alarm strobe in each building.
- 7) Provide additional recessed speakers throughout each building sufficient to ensure voice intelligibility throughout during notifications.
- 8) Manual alert activation stations shall be in the proximity of the main alarm panel and each alarm subpanel in each building (for a total of 3).
- 9) All equipment selections shall be submitted for review and approval.

Sequence of Operations

- 1) The manual alert activation is initiated.
- 2) The amber alert strobes shall be activated in all locations.
- 3) Voice communication shall be enabled at each command center – either live or pre-recorded.
- 4) Each panel (3) shall have provisions for alert deactivation.