



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM #2

RFQ #7603804

TITLE: DOT: FY20 CONSTRUCTION OF PREFABRICATED
STEEL STORAGE BUILDING

SUBMISSION DEADLINE: 6/01/2020 at 1:00pm

Question:

The building can't be built as design. The side wall with the large door openings need to have a portal frame brace bay. They don't have space between the column and door opening to accommodate the portal frame. Please advise.

Answer:

The Corle Building used as the basis of design does not require Portal Frames for the doors.

Marisa DelFarno

Marisa DelFarno
Buyer I