



State of Rhode Island
Department of Administration / Division of Purchases
One Capitol Hill, Providence, Rhode Island 02908-5855
Tel: (401) 574-8100 Fax: (401) 574-8387

ADDENDUM # 1

5/27/2020

Solicitation #7604775

Title: CCRI 6th Floor Roof Replacement, Knight Campus

Submission Deadline: June 11, 2020 @ 11:00 AM

Per the issuance of ADDENDUM #1 the following are noted:

Please find addendum #1 prepared by Aharonian & Associates Inc.
Clarification (see attached).

Interested Parties should monitor this website on a regular basis, for any additional information that may be posted.

Gary P. Mosca
Chief Buyer



AHARONIAN
& ASSOCIATES, INC.
Architects

May 26, 2020

TO: All Bidders

RE: CCRI 6TH FLOOR ROOF REPLACEMENT
KNIGHTCAMPUS
400 East Ave
Warwick, RI 02886
AA# 20029

ADDENDUM #1

CLARIFICATION:

Sheets A1.1, A1.2, A1.3 - Roof System A, All areas of roof insulation shall utilize tapered insulation to create a minimum pitch of ¼" per 1'-0". The minimum insulation thickness shall carry an LTTR of R-30. The base roof slope as well as the tapered crickets and sumps shall be provided as part of this contract for the entire work area. Whether noted or not all insulation shall be assumed to be tapered. GC Shall field verify tapered layout prior to ordering to ensure minimum roof pitch of ¼" per 1'-0" and proper drainage.

ATTACHMENTS
