



**State of Rhode Island  
Department of Administration / Division of Purchases  
One Capitol Hill, Providence, Rhode Island 02908-5855  
Tel: (401) 574-8100 Fax: (401) 574-8387**

**ADDENDUM # 3**  
**9/9/2020**

**RFQ# 7608804**

**TITLE: Lighting Project, Powers and Chapin Buildings**

**Submission Deadline has been postponed until:  
Monday September 28, 2020 2 PM (Eastern Time)**

---

**Notice: (Bid Bond is required for this project)**

**Attached is:**

- **Zoom information for public opening**
- **Questions received with responses**

**Thomas Bovis  
Interdepartmental Project Manager**

*Interested parties should monitor this website, on a regular basis, for any additional information.*

## **COVID-19 EMERGENCY PROTOCOL FOR BID OPENINGS**

Vendors and the public are advised that due to Covid-19 emergency social distancing requirements bid openings at the Division of Purchases shall be conducted via live streaming on the ZOOM website/application. Vendors and the public shall not be permitted to enter the Division of Purchases to attend bid openings. Vendors and the public who attend bid openings via live streaming shall be required to identify themselves and a record of all such attendees shall be maintained by the Division of Purchases. Vendor bid proposals shall be opened and read aloud at the date and time listed herein. The results of bid solicitations requiring a public copy for public works projects shall be posted on the Division of Purchases website as soon as possible after the bid opening. For RFP solicitations only vendor names shall be read aloud at the opening.

Vendors and the public are further advised that visitor access to the Powers Building at One Capitol Hill, Providence, RI requires pre-screening at the entrance to the building. In accordance with the Governor's Executive Order(s) and Department of Health emergency regulations all visitors to the Powers Building must wear a cloth mask which covers the nose and mouth. Vendors delivering bid proposals to the Division of Purchases should allow sufficient time for the pre-screening process. The Division of Purchases assumes no responsibility for delays caused by the screening process or any other reason. Vendors are solely responsible for on time delivery of bid proposals. The Division of Purchases shall not accept late bids for any reason.

Division of Purchases is inviting you to a scheduled Zoom meeting.

Topic: 7608804

Time: Sep 28, 2020 02:00 PM Eastern Time (US and Canada)

Join Zoom Meeting

<https://zoom.us/j/96654243662?pwd=S1c4UUIWVDN0RHkzTXhyajNXbkFIZz09>

Meeting ID: 966 5424 3662

Passcode: 071840

One tap mobile

+13126266799,,96654243662#,,,,,0#,,071840# US (Chicago)

+16465588656,,96654243662#,,,,,0#,,071840# US (New York)

Dial by your location

+1 312 626 6799 US (Chicago)

+1 646 558 8656 US (New York)

+1 301 715 8592 US (Germantown)

+1 346 248 7799 US (Houston)

+1 669 900 9128 US (San Jose)

+1 253 215 8782 US (Tacoma)

877 853 5247 US Toll-free

888 788 0099 US Toll-free

833 548 0276 US Toll-free

833 548 0282 US Toll-free  
Meeting ID: 966 5424 3662  
Passcode: 071840  
Find your local number: <https://zoom.us/j/abr4QGjwc>

## **RFQ 7608804 LIGHTING PROJECT, POWERS AND CHAPIN BUILDING**

**Question 1:** Powers Building- Please confirm the number of wall occupancy sensors to be removed/replaced with toggle switches.

**- For the purpose of this bid assume 50 units. Include a unit cost to adjust quantities as needed once field conditions are verified during the pre-construction walkthrough by the selected vendor.**

**Question 2:** Powers Building- At the walk through it was stated that there is enough slack such that new cabling would not be required to replace fixtures. Please confirm whether there are incidences where one fixture contains two ballasts and feeds a second fixture with a whip containing fixture wires. If so, what is the quantity and should we carry the cost to run properly sized branch conductors to the second fixture.

**- For the purpose of this bid, assume there are no instances where one fixture contains two ballasts and feeds a second fixture remotely with a whip containing fixture wires. The selected vendor may field verify this during their pre-construction walkthrough.**

**Question 3:** Powers Building- Referencing Fixture Schedule A, Line 3: (QTY 303 LED 4' Linear Bar Internal Driver) Do we need an incoming power kit for each?

**- For the purpose of this bid assume that yes, each will need an incoming power kit. The selected vendor may determine during their pre-construction walkthrough that some of these fixtures can be connected to each other with connector cables instead of using an incoming power kit for each; they will determine the quantities of each option at that time.**

**Question 4:** The invitation to bid indicates that a bid bond is not required; however, there was discussion of a bid bond at the pre-bid. Is a bid bond required?

**- Bid bond is required, Invitation to Bid was incorrect**