

**State of Rhode Island and Providence Plantations  
6/10/11**

**ADDENDUM NUMBER THREE**

**RFQ # 7448677**

**TITLE: ARRA-FIRE CODE UPGRADES, NAZARIAN CTR  
AND ROBERTS HALL, RI COLLEGE**

**Closing Date and Time: 6/16/11 at 2:00 PM**

**Per the issuance of this ADDENDUM # 3  
(3pages, including this cover sheet)  
The following change(s) are noted:**

**SEE ATTACHED**

**Specification Change /Addition / Clarification**

**DOCUMENT 00900 - ADDENDA AND MODIFICATIONS****ADDENDUM #3**

This document is the Third Addendum published for the Project. It hereby becomes a part of the Project Manual.

**PART 1 – GENERAL****1.1 PROJECT MANUAL**

A. Section 01500 Item 1 16B is deleted from the project manual.

B. Section 08710 Item 2.1 D is amended as follows:

Item	Scheduled Manufacturer	Acceptable Substitute
Cylinders & Keying	Medeco	No substitute

All other items in the table remain unchanged.

**1.2 DRAWINGS**

A. No drawings are issued as part of this addendum.

**1.3 CONTRACTOR QUESTIONS**

A. The following is a list of questions received by the Division of Purchasing regarding this solicitation:

- a. Q: Section 01200 notes a unit price. For each door type, provide a unit price for the installation of a new door frame. Where on the Bid Form are we to include? Would that be a hollow metal frame for a single door and for a pair of doors? *A: Please attach a separate sheet(s) that addresses the unit prices to the Bid Form. Yes, please provide unit prices for each of the different types of doors identified in the bid documents.*
- b. Q: Section 01500 notes Temporary Fence to be located where shown on Drawing A0 1. Set of drawings do not include A0.1 or noted on any of the drawings. Are we to include? *A: No, this Addendum deletes Section 01500 1.16B.*
- c. Q: There are no notes on the stairwells for railing replacement and flooring replacement. Which ones get the new railings and flooring? *A: Please see the drawings notes for Stairs 3 & 4 on A4-100a & A4-101 and for Stairs 1 & 2 on A4-100b & A4-101.*
- d. Q: Will any areas require after hours or weekend work? If so, please identify those areas. *A: Every effort will be made to accommodate construction during normal working hours; however, some after hours or weekend work may be required. The need for after hours or weekend work will depend upon the college's schedule and*

*the proposed construction schedule. The details of the construction schedule will be coordinated between the college and the contractor after the contract has been awarded but before work has commenced.*

- e. Q: Please verify that Doors #D151A and D251A will require a new HM door frame. There is no frames noted in the Door Schedule but the doors are installed in new partitions. A: *Yes, new door frames are required for those 60-minute fire resistance rated doors.*

1.4 DISTRIBUTION: By RI State Purchasing via website.

**END OF DOCUMENT 00900**