

State of Rhode Island and Providence Plantations

6/2/09

ADDENDUM NUMBER 1

RFQ # 7243892

TITLE: New Roofing-Gilbreth Hall, URI

Closing Date and Time: 6/10/09 at 1:45 PM

Per the issuance of ADDENDUM # 1 the following change(s) are noted:

Specification Change /Addition / Clarification

Attached is a copy of the (1) page Addendum which has also been posted on the State Purchasing Website at www.purchasing.ri.gov.

The actual addendum, in its entirety, will be distributed to the plan holders on record at the Department of the RI State Building Code Commission, One Capitol Hill, Providence, RI. (Phone (401) 222-3028)

DOCUMENT 00900

ADDENDUM NO. 1

JUNE 2, 2009

PROJECT: New Roofing
Gilbreth Hall
University of Rhode Island
Kingston, Rhode Island

- This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated March 11, 2009 as noted below
- Please advise all sub-contractors.
- Acknowledge receipt of this Addendum in the space provided on the Bid Form
- When returning Drawings and Project manual upon completion of bidding, please include this Addendum

PROJECT MANUAL

ITEM NO. 1 – SECTION 07525 – SBS MODIFIED BITUMINOUS ROOFING

- A Paragraph 2 01 B 1: Delete “IKO Roofing Products” and substitute with the following as acceptable manufacturers offering equivalent products:
- 1 Certainteed
 - 2 Johns Manville
 - 3 Siplast

DRAWINGS

ITEM NO. 1 – DRAWING A1

- A Provide and install sleepers as required for two existing small, lightweight air conditioner condensers not shown on the plan. Condensers are to be mechanically attached to new sleepers. Provide a penetration seal at pipe associated with each of the condensers. One penetration seal per condenser. Use the ChemCurb system (or equal) as specified and similar to that as shown in drawing detail A/A2

END OF DOCUMENT